



Ref. Certif. No.

**SI-6907**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Surface mounted installation boxes
Name and address of the applicant	Tehnoplast d.o.o. Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia
Name and address of the manufacturer	Tehnoplast d.o.o. Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia
Name and address of the factory	Tehnoplast d.o.o. Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia
<i>Note: When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	400 V a.c. or 1000 V d.c.; IP65; IK08
Trademark (if any)	TEHNOPLAST
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	N4D, N8D, N12D, N24D, N36D
Additional information (if necessary may also be reported on page 2)	/
A sample of the product was tested and found to be in conformity with	<input checked="" type="checkbox"/> Additional Information on page 2 IEC 62208:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	T211-0929/18 dated 2018-11-19

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Tržaška cesta 2, SI-1000 Ljubljana, Slovenia  
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2018-11-19

Signature: Bojan Pečavar

**List of models and ratings:**

Type	Size: width x height x depth (mm)
N4D	128 x 201 x 120
N8D	202 x 201 x 120
N12D	319 x 256 x 144
N24D	319 x 384 x 144
N36D	319 x 535 x 144

**Declared static load and Pde:**

Type	Static load per DIN rail	Pde
N4D	0,65 kg	10 W
N8D	1,3 kg	13 W
N12D	1,95 kg	16 W
N24D	1,95 kg	24 W
N36D	1,95 kg	26 W

**Materials used:**

- Terminals (BASF type Ultramid KR 4450)
- Enclosure (LG type LI911)

Additional information (if necessary)

Date: 2018-11-19

Signature: Bojan Pečavar

