

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Flush mounted installation boxes

Name and address of the applicant
Nom et adresse du demandeur

Tehnoplast d.o.o.
Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia

Name and address of the manufacturer
Nom et adresse du fabricant

Tehnoplast d.o.o.
Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia

Name and address of the factory
Nom et adresse de l'usine

Tehnoplast d.o.o.
Zdravka Jekića 119, RS-22305 Stari Banovci, Serbia

*Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2ème page*

Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

400 V; IP40; Class II

Trademark (if any)
Marque de fabrique (si elle existe)

TEHNOPLAST

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.
Ref. De type

U12-FS, U24-FS, U36-FS, U12-FP, U24-FP, U36-FP, U12-FSW,
U24-FSW, U36-FSW, U12-FPW, U24-FPW, U36-FPW

Additional information (if necessary may also be reported
on page 2)

Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60670-24:2011 (2nd Ed.)
IEC 60670-1:2002 (1st Ed.) + A1:2011

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

T211-0658/15


This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



SIQ Ljubljana
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si
Product Certification Body is accredited by Slovenian Accreditation, Reg. No.: CP-001

Date: 2015-12-07

Signature: Bojan Pečavar



Description of types:

Type	Resistance of insulating material to abnormal heat and to fire (enclosure) – except terminals (960°C)	Color of front door	Size: width x height x depth (mm)
U12-FS	650°C	Transparent	346 x 274 x 88
U24-FS	650°C	Transparent	442 x 274 x 88
U36-FS	650°C	Transparent	592 x 274 x 88
U12-FP	850°C	Transparent	346 x 274 x 88
U24-FP	850°C	Transparent	442 x 274 x 88
U36-FP	850°C	Transparent	592 x 274 x 88
U12-FSW	650°C	White	346 x 274 x 88
U24-FSW	650°C	White	442 x 274 x 88
U36-FSW	650°C	White	592 x 274 x 88
U12-FPW	850°C	White	346 x 274 x 88
U24-FPW	850°C	White	442 x 274 x 88
U36-FPW	850°C	White	592 x 274 x 88

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2015-12-07

Signature: Bojan Pečavar

